

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch

690 Walnut Ave.St. 150

Vallejo, CA 94592-1133

(707) 649-5453

(707) 649-5493

Contract #: 04-0120F4Cty: SF/ALA Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:**Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-024194**Date Inspected:** 31-May-2011**Project Name:** SAS Superstructure**OSM Arrival Time:** 700**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 1900**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** Li Yang**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Orthotropic Box Girder (OBG)**Summary of Items Observed:**

On this date Caltrans Office of Structural Material (OSM) Quality Assurance (QA) Inspector, D.Sukanthan was present during the time noted above for observations relative to the work being performed.

OBG # BAY 10

This QA inspector received ZPMC Non Destructive Testing (NDT) notification 09316 to perform Magnetic particle Testing (MT) of approximately 15% of the area previously tested and accepted by ZPMC Quality Control Personnel. This QA Inspector generated a Magnetic particle Test report for this date. The member is identified as Bike Path. The weld tested is identified as follows:

(BK010A-001-004,009,005,006,033,034,035,036)

OBG # BAY 9

This QA inspector received ZPMC Non Destructive Testing (NDT) notification 09317 to perform Magnetic particle Testing (MT) of approximately 15% of the area previously tested and accepted by ZPMC Quality Control Personnel. This QA Inspector generated a Magnetic particle Test report for this date. The member is identified as Traveler bracket. The weld tested is identified as follows:

(TB3002-001-001)

(TB3002-001-002)

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

(TB3003-001-001)

(TB3003-004-002)

(TB3004-001-002)

(TB3004-004-002)

This QA Inspector randomly observed the following work in progress:

OBG # CROSSBEAM CB19

This QA observed ZPMC qualified welding personnel identified as 220063 perform Flux Cored Arc Welding (FCAW) Process on weld joint BP3099-1-019-007,008. ZPMC Quality Control Personnel (QC) identified as Mr. Liyang was present to monitor the welding process. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-2132-ESAB.

This QA observed ZPMC qualified welding personnel identified as 220063 perform Flux Cored Arc Welding (FCAW) Process on weld joint BP3099-2-019-007,008. ZPMC Quality Control Personnel (QC) identified as Mr. Liyang was present to monitor the welding process. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-2132-ESAB.

This QA observed ZPMC qualified welding personnel identified as 220063 perform Flux Cored Arc Welding (FCAW) Process on weld joint BP3099-2-019-011,012. ZPMC Quality Control Personnel (QC) identified as Mr. Liyang was present to monitor the welding process. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-2132-ESAB.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.

Summary of Conversations:

As mention above

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang 150-00422372, who represents the Office of Structural Materials for your project.

Inspected By:	Sukanthan,Dhanasingh	Quality Assurance Inspector
----------------------	----------------------	-----------------------------

Reviewed By:	Hall,Steven	QA Reviewer
---------------------	-------------	-------------